



BRACKET DATA

CATALOG NUMBER	PIPE SIZE (IN)	WALL THK. (IN)	NOMINAL LENGTH	"L" (IN)	"R" (IN)	"S" (IN)	BRACKET CLASS PER ANSI C136.13-1992 ¹
ASG-200-060	2.00	0.140	6'-0"	66	24	20	G
ASG-200-080	2.00	0.140	8'-0"	90	30	22	D

¹The EPA rating for the arm utilizes the classification as described in ANSI C136.13-1992, American National Standard for Roadway Lighting - Metal Brackets for Wood Poles. Please contact Valmont Industries if a greater EPA is required.

SPECIFICATIONS

Pipe Arm

The luminaire arm is manufactured from 2-3/8" O.D. (2" pipe size) x 0.14" wall (6063-T6 alloy). The tube is heat treated after bending to produce a T6 temper.

Extrusions

All extrusions including the brackets and hook are manufactured from extruded 6061-T6 alloy.

Steel Hardware

All steel components are galvanized meeting ASTM A153.

It is recommended that the through bolt attachment be used in conjunction with the bottom two lag bolts installed in the bottom holes of the bracket.

Check with the original pole manufacturer for maximum load rating for the pole prior to installing the arm.

All brackets include provision for grounding.

CATALOG LOGIC

Material	Series	Pipe Size	Arm Length
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

Material	Series	Pipe Size	Arm Length
A - Aluminum	SG - Single Guy Rod	200 - 2.00"	060 - 6'0" 080 - 8'0"

Customer Approval:

signature _____ date _____

Job Name: _____ Quote: _____
 Client Name: _____
 Created By: _____ Date: _____